

Viscor Inc 35 Oak Street

Toronto, ON Canada M9N 1A1 Tel: 416.245.7991 Fax: 416.245.4778 www.viscor.com

Title: KIT00093

ERP# IIS00181 Date: FEB 2017

WARNINGS

Electric shock:

- Disconnect or turn off power before installing or servicing luminaire.
- All electrical wiring to be completed by a qualified licensed electrician in accordance with local and National/Canadian Electrical Code.
- Ensure supply voltage corresponds with the correct ballast/driver voltage.
- Avoid exposing wiring to metal edges and sharp objects.
- Ensure that the luminaire is properly grounded to prevent electric hazards.

Fire:

- Keep flammable and combustible materials away from the light source and/or lens.
- Use correctly rated supply conductors as indicated by product labeling.

Burn:

Allow luminaire to cool before handling luminaire.

Personal Injury:

- Wear safety glasses and gloves when handling the luminaire to avoid physical injury.
- Avoid direct eye contact with light source.
- Always support the weight of the luminaire.

KIT00093

MOUNTING 45 DEGREE BRACKET.M43 (x 2 pieces) 2X LHBV RIGID MOUNTING BEAM

2X RIVNUTS


2X 8-32 x .5 LENGTH FASTENERS


For use with the **LHBV Series**


45 DEG. BRACKET

DOUBLE KEYHOLE FOR MOUNTING **DOWNLIGHT OR UPLIGHT**

RIGID MOUNTING BEAM







The Viscor Group







